



1. LOCATING WIRE SHALL BE BURIED DIRECTLY ABOVE THE CENTERLINE OF THE PIPE.
2. LOCATING WIRE SHALL BE CONTINUOUS, INSULATED SOLID CORE METALLIC (10 GAGE COLOR CODED COPPER) SUITABLE FOR DETECTION VIA A CABLE LOCATOR.
3. LOCATING WIRE SHALL TERMINATE AT THE TOP OF EACH VALVE BOX ENCASED IN 2" PVC AND EMBEDDED IN THE CONCRETE COLLAR. (SEE DETAILS C-18A AND C- 18B)
4. LOCATING WIRE IS NOT REQUIRED FOR GRAVITY SEWER.

PIPE LOCATING WIRE